

SMOKE-RATED ASTRAGAL SEALS





- Fire-Rated Astragal Seals Cannot Replace any Astragal Required on the Door by the Door Manufacturer to Maintain its Fire Label. IBC, NFPA 80, NFPA105, and NFPA 252 Require the Gap at the Meeting Edge Between Fire Labeled Doors Must Not Exceed 1/8"
- #6 x 3/4" Stainless Steel Sheet Metal Screws Furnished
- Screw Holes Slotted for Adjustment

METAL	EPDM	NEOPRENE	SILICONE	NYLON+
A - Anodized Aluminum	Black	Black	Black	Gray
DKB - Dark Bronze / Black Anodized	Black	Black	Black	Black
No Suffix - Mill Aluminum	Black	Black	Black	Gray

-BB = Black Brush


5070B Brown Self-Adhesive Silicone

5070CL Clear Self-Adhesive Silicone



115NA
115NDKB
EPDM
BHMA CERTIFIED


Provided as Two-Piece Set



137NA
137NDKB
Neoprene


Order as **Set** to Receive Two Pieces

137SA
137SDKB
Silicone




125NA
125NDKB
EPDM
BHMA CERTIFIED

Provided as Two-Piece Set




9600
9600A
9600A-BB
9600DKB
BHMA CERTIFIED

Order as **Set** to Receive Two Pieces




9115A
9115DKB
Silicone
BHMA CERTIFIED

Provided as Two-Piece Set




9605A
9605A-BB
9605DKB
BHMA CERTIFIED

Order as **Set** to Receive Two Pieces



9125A
9125DKB
Silicone
BHMA CERTIFIED

Provided as Two-Piece Set



672NA
672NDKB
Neoprene

Order as **Set** to Receive Two Pieces