



NCP 9750

Fire and Smoke Seal



- Self-Adhesive Intumescent
- Flame Resistant
- 1/2" Wide x 3/16" Tall
- Available in 36", 48", 84", 96" and 108" Lengths

SEAL



See ngp.com for All Applicable Certifications for this Product.



POSITIVE PRESSURE TESTED GASKETING MATERIALS FOR FIRE DOORS FOR APPLICATION TO HOLLOW-METAL-TYPE FIRE DOORS RATED UP TO 3 HOURS AND WOOD-TYPE FIRE DOORS RATED UP TO 1 1/2 HOURS. CATEGORY C, H

SMOKE AND DRAFT CONTROL GASKETING (CATEGORY H) TESTED TO UL 1784; MEETS REQUIREMENTS OF NFPA 105, IBC FOR USE ON "S" LABEL DOORS.



POSITIVE PRESSURE TESTED MISCELLANEOUS FIRE DOOR ACCESSORY

For use on 20 minute UL10B, UL10C and CAN/ULC-S104 wood or hollow metal fire doors with head and/or jamb clearance exceeding 1/8", up to 5/16".


An NCP strike shim 9275 or 9225 may be required for proper latchbolt engagement.

Hinge edge of category B wood doors requires a UL certified category C edge seal.

ngp.com
1-800-NCP-RUSH

INSTALLATION INSTRUCTIONS

9750



20, 45, 60, 90 Minute Rated Category
B Wood Doors Perimeter Application
Up To:

Single Swing 4'0 X 9'0

Pairs 8'0 X 9'0

UL Tested and Classified for
Fire and Smoke Doors.

* Seals against smoke, fire, air
and weather.

* Excellent compression; door
latches easily.

1. The surface temperature of
the frame must be above
50°F for the adhesive to
bond properly.
2. Clean frame with clean wipe
provided to remove dust,
oil, grease and dirt. Wax
coated or high gloss painted
surfaces may require
roughening of the surface
with a scotch brite pad or
sandpaper so adhesive will
properly bond.
3. Measure and pre-cut pieces
to fit where seal is to mount.
4. Remove protective backing
1 to 2 feet at a time.
5. Position on frame where
illustrated.
6. Adhere by pressing firmly
(approx. 15 lbs. pressure
required) straight down
along entire length of
gasketing.
Do not remove and relocate.
7. Make sure the seal does not
impede proper closing and
latching of the door.



ngp.com

1-800-NGP-RUSH

FAX: (800) 255-7874

QUOTES: quotes@ngp.com

ORDERS: orders@ngp.com

MEMPHIS

4985 East Raines Road
Memphis, TN 38118

CARSON CITY

3689 Arrowhead Drive
Carson City, NV 89706