



9750

Gap Solution For Excessive Fire Door & Frame Clearances —20 Minutes Up To $\frac{5}{16}$ "

PRODUCT CUT SHEET

Material

Self-Adhesive Intumescent

- ▶ UL Certified Solution for 20-Minute Fire Doors with Excessive Clearance Between Door and Frame Over $\frac{1}{8}$ ", up to $\frac{5}{16}$ "
- ▶ For Use on 20-Minute Rated UL10B and UL10C Wood or Hollow Metal Fire Doors
- ▶ Multiple Strike Shims 9275 or 9225 May Also be Required for Proper Latchbolt Engagement
- ▶ NGP Intumescent Materials are Formulated to Expand at 275°F up to 20 Times Their Original Thickness, Completely Sealing the Gap Around and Between Doors During a Fire
- ▶ Provides Strong Initial Adhesion and Outstanding Long-Term Holding Strength for Secure, Permanent Bonding in Both Interior or Exterior Applications
- ▶ Resistant to Aging, Weathering, UV Radiation, Water, Detergent, Alcohol, and the Influence of Chemicals
- ▶ Available in 36", 48", 84", 96" and 108" Lengths

Color

9750C Charcoal



20, 45, 60, 90 Minute Rated Category
B Wood Doors Perimeter Application
Up To:
Single Swing 4'0 X 9'0
Pairs 8'0 X 9'0

- ▶ NGP-Edge® Sealing System/
Smoke and Draft Control Gasketing
Category "G" and "H" Classified



NATIONAL GUARD PRODUCTS, INC.

MEMPHIS

4985 East Raines Road
Memphis, TN 38118



CARSON CITY

3689 Arrowhead Drive
Carson City, NV 89706

Fax: (800) 255-7874
Email: info@ngp.com

Quotes: quotes@ngp.com
Orders: orders@ngp.com

PROJECT:
SUBMITTED BY:
DATE:
NOTES:



NGP-GKT-9750-PCS-0426-A

ngp.com
1-800-NGP-RUSH