

GAP90-ME

MEETING EDGE AND PERIMETER GAP SOLUTION – WOOD & HOLLOW METAL



UL CERTIFIED FOR USE IN
THE US AND CANADA

**Application Certified for Fire Doors
and Frames with Excessive Clearance
up to $\frac{3}{8}$ ".**

- Application Certified for Fire-Rated Hollow Metal Doors, Frames and Wood Doors with Excessive Clearances up to $\frac{3}{8}$ "
- Non-Handed
- Certified for use on Doors with Surface/ Concealed Vertical Rod Exit Devices or Manual/Automatic Flush Bolts (see *Installation Instructions*)
- Door Removal Not Required
- Can be Field-Modified to Match-Fit Varying Gaps Along Height or Width of the Door (see *installation instructions*)
- Patented: US Patent US 11,885,175 B2

PRODUCT CONSISTS OF:

- + Formed Metal Edge, 20-Gauge Steel, Embossed With UL Mark
 - + Powder Coated, Primer Gray
 - + Hardware Pack
 - #10 x $\frac{3}{4}$ " FHPH SS TEK
 - #10 x $2\frac{1}{2}$ " FHPH SS SMS
 - + GapGuard Fire Caulk (see *Installation Instructions*)
- (Required on Wood Door Application Only)



POSITIVE PRESSURE TESTED
MISCELLANEOUS FIRE DOOR
ACCESSORY



SPECIAL NOTES:

- 90-Minute Rated UL Certified Miscellaneous Fire Door Accessory on UL10B and UL10C Wood or Hollow Metal Fire Doors.
- An NGP Strike Shim 9275 or 9225 may also be Required for Proper Latchbolt Engagement.
- Certified for On-site Modifications Around Strike Location.
- If Fire Pins are used, it is Recommended to Apply Metal Edge to Door with Fire Pin Receiver, Ensuring Receiver is Flush with Metal Edge.
- To Retain UL Certification, the Gap90-ME must be Installed using GapGuard Fire Caulk on wood door applications.

Formed
Metal Edge

Formed
Metal Edge



$\frac{1}{2}$ " x $1\frac{1}{2}$ " Cylindrical
Anchoring Bore Filled With
GapGuard Fire Caulk
(fire caulk only required on
wood door application)

$\frac{1}{2}$ " x $\frac{1}{2}$ " Cylindrical
Anchoring Bore Filled With
GapGuard Fire Caulk
(fire caulk only required on
wood door application)

WOOD DOOR INSTALLATION SHOWN

$\frac{1}{2}$ " x $1\frac{1}{2}$ " Cylindrical
Anchoring Bore Filled With
GapGuard Fire Caulk
(fire caulk only required on
wood door application)